

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

Broj / Number: C 2105

Strana / Page: 1/3

Na zahtev naručioca / **HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse**
By the request of purchaser: **3-5, Austria**

preduzeto je / kontrolisanje postojećeg proizvoda / *inspection of existing product*
set to:

u vezi sa Izveštajem o kontrolisanju / TUV Rheinland LGA Nr.7311040-11z
in relation to Inspection report:

sa priloženim dokumentima / - Izvod iz prospekt proizvoda /
with attached documents: *Catalogue pages of product ;*

INSTITUT "MIHAJLO PUPIN" - CENTAR ZA GASNU TEHNIKU izjavljuje da:
INSTITUTE "MIHAJLO PUPIN" - GAS TECHNIQUE CENTRE declares that:

predmet kontrolisanja / **KROVNI SLIVNICI /**
the inspection object : **ROOF DRAINS**

proizvođač / **HL Hutterer & Lechner GmbH, 2325 Himberg, Brauhausgasse**
manufacturer: **3-5, Austria**

oznaka modela / **HL62, HL64, HL69, HL80.3**
mark of the model :

kako je specificirano u Prilogu A, zadovoljava zahteve navedene u /
as specified in the Annex A, meets the requirements described in:

referentnom dokumentu /
reference document : **SRPS EN 1253-2 :2016**

Nadzor usaglašenosti predmeta kontrolisanja se obezbeđuje sa
periodičnim kontrolisanjem do dana /
Surveillance of the inspection object compliance is assured by periodical
inspection until the date :

26.05.2026. god.

izdat od / issued by :

RUKOVODILAC CENTRA ZA GASNU TEHNIKU
GAS TECHNIQUE CENTRE MANAGER

mesto, datum / place, date :

Beograd, 26.05.2021. god.

M.P. / S.P.

Kristina Petković, dipl. maš. inž.

Ime, Prezime / Name, Surname

Inspection certificate

Sertifikat o kontrolisanju

INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
LABORATORIJA
Volgina 15
BEOGRAD
SRBIJA
tel: +381 11 6772 151
fax: +381 11 6781 029
impcgt@pupin.rs



CGT 4.001 V.8

SERTIFIKAT O KONTROLISANJU **INSPECTION CERTIFICATE**

Broj / Number: **C 2105**

Strana / Page: **2/3**

Prilog A / Annex A

Pregled proizvoda u okviru modela / *Product review of the model*

oznaka modela / mark of the model:	dimenzije* / dimensions: d _s (mm)	težina / weight: (g)	kratak opis / short description:
HL62 (/ , H, P, F)	DN 75/110/125 /160	1307 - 2001	– krovni slivnik u izvedbi sa ili bez samoregulišućeg grejača snage 10 - 30 W, sa vertikalnim odvodom i hvatačem lišća, / <i>roof drains with or without self-regulated heater 10 - 30 W, with vertical drainage and lives seizer,</i> – sa (HL62 - H) ili bez (HL62 - / , P i F) bitumenske kragne, / <i>with (HL62 - H) or without (HL62 - / , P and F) bitumen collar,</i> – izrađen od PP (polipropilen, HL62 - / , H, i F) i PVC + PP (H62P), kućište slivnika toplotno izolovano, / <i>made of PP (polypropilene, HL62 - / , H, and F) and PVC+PP (H62 - P), insulated drain body,</i> – kapaciteti - HL62, HL62H: 9,9 - 14,1 l/s, HL62P: 7,4 - 11,1 l/s, HL62F: 7,4 - 10,75 l/s. / <i>capacities - HL62, HL62H: 9,9 - 14,1 l/s, HL62P: 7,4 - 11,1 l/s, HL62F: 7,4 - 10,75 l/s.</i>
HL64 (/ , H, P, F)	DN 75/110	1639 - 2095	– krovni slivnik u izvedbi sa ili bez samoregulišućeg grejača snage 10 - 30 W, sa horizontalnim odvodom i hvatačem lišća, / <i>roof drains with or without self-regulated heater 10 - 30 W, with horizontal drainage and lives seizer,</i> – sa (HL64 H) ili bez (HL64 - / , P, F) bitumenske kragne, / <i>with (HL64 - H) or without (HL64 - / , P, F) bitumen collar,</i> – izrađen od PP (polipropilen, HL64 - / , H, i F) i PVC + PP (H64P), kućište slivnika toplotno izolovano, / <i>made of PP (polypropilene, HL64 - / , H, and F) and PVC+PP (H64 - P), insulated drain body,</i> – kapaciteti - HL64, HL64H: 10,0/6,0 l/s, HL64P, HL64F: 6,9/7,8 l/s. / <i>capacities - HL64, HL64H: 10,0/6,0 l/s, HL64P, HL64F: 6,9/7,8 l/s.</i>
HL69 (/ , H, P)	DN 75/110/125 /160	1523 - 2845	– krovni slivnik za sanaciju ravnog krova sa vertikalnim odvodom i hvatačem lišća, / <i>roof drain for renovation of flat roofs with vertical drainage and lives seizer,</i> – sa (HL69 H) ili bez (HL69 - / , P) bitumenske kragne, / <i>with (HL69 - H) or without (HL69 - / , P) bitumen collar,</i> – izrađen od PP (polipropilen, HL69 - / , H) i PVC (H69P), kućište slivnika toplotno izolovano, / <i>made of PP (polypropilene, HL69 - / , H, and F) and PVC+PP (H69 - P), insulated drain body,</i> – kapaciteti - HL69, HL64H: 7,5 - 10,3 l/s, HL64P: 6,34 - 9,0 l/s. / <i>capacities - HL69, HL64H: 7,5 - 10,3 l/s, HL64P: 6,34 - 9,0 l/s.</i>

* - dimenzija izlaznog priključka / *dimension of outlet socket*

Inspection certificate
Sertifikat o kontrolisanju

SERTIFIKAT O KONTROLISANJU **INSPECTION CERTIFICATE**

Broj / Number: **C 2105**

Strana / Page: **3/3**

oznaka modela / mark of the model:	dimenzije / dimensions: d _s (mm)	težina / weight: (g)	kratak opis / short description:
HL80.3 (/ , H)	DN 50/75	550	– krovni slivnik sa podešavajućim priključkom i hvatačem lišća, / <i>roof drain with adjustable position of socket (horizontal to vertical) and leaves seizer,</i> – sa (HL80.3 H) ili bez (HL80.3) bitumenske kragne, / <i>with (HL80.3H) or without (HL80.3) bitumen collar,</i> – izrađen od PP (polipropilen, HL80.3H) i PP+PE (polyethylene) (H80.3), kućište slivnika toplotno izolovano, / <i>made of PP (polypropylene, HL80.3H) and PP+PE (H80.3), insulated drain body,</i> – kapaciteti - HL80.3, HL80.3H: 1,0 l/s. / <i>capacities - HL80.3, HL80.3H: 1,0 l/s. /</i>

* - dimenzija izlaznog priključka / *dimension of outlet socket*

Inspection certificate

Sertifikat o kontrolisanju